Single
Packs

Single Pack KLF6.6CNHS 115-127V 60Hz CSIR

Single pack code number: **195B4845**

Position	Title	Code	Amount
1	Compressor KLF6.6CNHS	106H3703	1
2	Starting capacitor (240µF 125V, 6.3mm)	117U5002	1
3	Starting relay (QLZ-11.6A, overload protector T1141/L6)	117U7076	1
4	KL accessories	103N1060	1
5	Bolt joint for one compressor | M6 | ø16mm	118-1917	1

Secop GmbH • Lise-Meitner-Straße 29 • 24941 Flensburg, Germany • Tel: +49 461 4941 0 • **www.secop.com**

Secop accepts no responsibility for possible errors in catalogs, brochures, and other printed material. Secop reserves the right to alter its products without notice. This also applies to products already on order provided that such alterations can be made without subsequential changes being necessary to specifications already agreed. All trademarks in this material are the property of the respective companies. Secop and the Secop logotype are trademarks of Secop GmbH. All rights reserved.

Model
KLF6.6CNHS

Sales code:
106H3703

Compressor Data

Refrigerant(s)	**R290**
Refr. charge - tech. limit	**200g / 7.05oz**
Weight	**9.50 kg / 20.94lbs**
Displacement	**6.60 cm3 / 0.40cu.in**
Compressors on pallet	**100**



General – Configurations With KLF6.6CNHS

–	**Conf. 1**
Motor configuration	CSIR
Power supply (nominal)	115-127 V/60 Hz
Number of phases	1
Voltage range	95-140 V
Approvals	UL, CCC
Starting torque	HST
Refrigerant	R290
Application	LBP+MBP
Hot gas defrost	OK
Long interval pull down	OK

Application Notes

- Provision for PE Grounding is located at the PE Stamp on the compressor
- Very good robustness against liquid intake.
- Ice-cube maker optimization - indirect suction intake.

Model
KLF6.6CNHS

Sales code:
106H3703

Compressor Design


Oil type	**POE**	Winding resistance main	**2 Ohm**
Oil viscosity	**9,7cSt**	Winding resistance aux	**5.3 Ohm**
Oil quantity	**165 / 5.58fl.oz**	Max. winding temp.	**125 °C**
Free gas volume comp.	**1,580 cm3 / 53.43fl.oz**	Max. discharge temp.	**130°C / 266°F**
Motor protection	**external**		

Compressor Dimensions

Housing


A Height	**182mm / 7.17in**
B Height	**175mm / 6.89in**
C Length shell	**198mm / 7.80in**
D Length w. cover	**238mm / 9.37in**
E Width	**160mm / 6.30in**

Find 3D Model here




Connectors	Suction X	Discharge Y	Process Z
Diameter [mm]	øi 8.11–8.29 / 0.32–0.33in	øi 6.41–6.59 / 0.25–0.26in	øi 6.41–6.59 / 0.25–0.26in
Material	CU	CU	CU
Horizontal angle ±2°	35°	13°	0°
Vertical angle ±2°	30°	40°	145°
Position l/h/w [mm]	119/73/59 / 4.69/2.87/2.32in	117/107/66 / 4.61/4.21/2.60in	-88/101/71 / -3.46/3.98/2.80in
Straight tube l. [mm]	13.5 / 0.53in	13.5 / 0.53in	13.5 / 0.53in

Mounting Accessories




Dimensions in mm [in]

Bolt joint



Snap-on



	one comp.	multi pack
Bolt joint | M6 | ø16mm	118-1917	118-1918
Bolt joint | ø1/4" | ø16mm	118-1946	–
Bolt joint | ø1/4" | ø19mm	118-1949	–
Snap-on | ø7,3 | ø16mm	118-1947	118-1919

Model
KLF6.6CNHS Configuration 1

Sales code:
106H3703


Configuration

Motor configuration	**CSIR**
Power supply (nominal)	**115-127 V/60 Hz 1~**
Refrigerant	**R290**
Application	**LBP+MBP**
Voltage range	**95-140 V**
Starting torque	**HST**
Approvals	**UL, CCC**
Starting device type	**relay**
Run capacitor	**-/-**
Start capacitor	**240 µF**
LRA (locked rotor amps / 4s/ U(N))	**31.1 A**
RLA (rated load amps / 1s/ U(N))	**4.3 A**
Cut in current (U(N))	**31.5 A**

Ambient/ machine room temperatures minimum /maximum
Ambient temperature range: 10 - 43°C / 50 - 109°F
Machine room temp. compressor: 10 - 48°C / 50 - 118°F

System Cooling
fan 3m/s

Electrical Accessories / Wiring Diagram





View full size

Components
a5 current relay (T1141/L6-S6) 117U7076
c start capacitor (240µF) 117U5002
b, d cover + clamp + screws (5VA-compl.) 103N0600

Alternative components
b, d 100x cover + clamp + screws (5VA) 103N2060
b, d cover + clamp + screws (5VA) in bag 103N1060

Operation Pressure Range





Model
KLF6.6CNHS Configuration 1

Sales code:
106H3703

Standard Conditions

R290, 115 V/60 Hz, CSIR, fan 3m/s

pe	pc	RGT	Tliq	Cooling capacity			COP	EER	P	I	ṁ	
[°C] [°F]	[°C] [°F]	[°C] [°F]	[°C] [°F]	[W]	[Btu/h]	[kcal/h]	[W/W]	[Btu/Wh]	[W]	[A]	[kg/h]	
-23.3 -10	54.4 129.9	32.2 90	32.2 90	**385**	1314	331	**1.58**	5.39	244	3.15	3.91	**ASHRAE LBP**
-25 -13	55 131	32 89.6	55 131	**287**	979	247	**1.23**	4.19	234	3.09	3.60	**CECOMAF LBP**
-35 -31	40 104	20 68	40 104	**217**	739	186	**1.17**	4.01	185	2.86	2.49	**EN12900 LBP**
-6.7 20	54.4 129.9	35 95	46.1 115	**692**	2362	595	**2.02**	6.91	342	3.80	7.93	**ASHRAE MBP**
-10 14	55 131	32 89.6	55 131	**548**	1870	471	**1.69**	5.75	325	3.68	6.97	**CECOMAF MBP**
-10 14	45 113	20 68	45 113	**618**	2108	531	**2.01**	6.85	308	3.56	7.60	**EN12900 MBP**

Performance Tables


R290, 115 V/60 Hz, CSIR, fan 3m/s

pc= 45/113 | RGT= 32/89.6 | Tliq= 45/113 | °C/°F

pe		Cooling capacity			COP	EER	P	I	ṁ
[°C]	[°F]	[W]	[Btu/h]	[kcal/h]	[W/W]	[Btu/Wh]	[W]	[A]	[kg/h]
-40	-40	**156**	533	134	**0.96**	3.29	162	2.77	1.75
-30	-22	**268**	913	230	**1.29**	4.39	208	2.96	3.02
-20	-4	**427**	1456	367	**1.65**	5.62	259	3.25	4.86
-10	14	**642**	2191	552	**2.09**	7.12	308	3.56	7.37
0	32	**923**	3149	794	**2.67**	9.11	346	3.83	10.73
7.2	45	**1170**	3993	1007	**3.23**	11.03	362	3.95	13.77

pc= 55/131 | RGT= 32/89.6 | Tliq= 55/131 | °C/°F

-40	-40	**135**	461	116	**0.90**	3.06	151	2.71	1.68
-30	-22	**226**	769	194	**1.11**	3.78	204	2.93	2.82
-20	-4	**360**	1229	310	**1.36**	4.65	264	3.28	4.53
-10	14	**548**	1870	471	**1.69**	5.75	325	3.68	6.97
0	32	**798**	2722	686	**2.11**	7.21	377	4.07	10.29
7.2	45	**1021**	3484	878	**2.52**	8.59	405	4.29	13.34




KL Compressors


SECOP

Keep electrical equipment clear from oil, chemicals, and water


When operated with a flammable refrigerant, only spark-proof starting equipment is allowed.


RSIR







RSCR






CSIR







KL Compressors

SECOP


Keep electrical equipment clear from oil, chemicals, and water

When operated with a flammable refrigerant, only spark-proof starting equipment is allowed.

Service/Repair – R290, R600a, R170, R1270, R1234yf

(applies to all flammable refrigerants)





Dismantling, recycling, disposal: At the end of a compressor's lifecycle, proceed by separating and storing components according to their environmental impact. Parts that may cause pollution must be clearly identified and handled separately, ensuring appropriate disposal. Refrigerant gas must not be released into the environment and should be recovered by qualified operators. Compressor oil must also be collected separately. The compressor should be disposed of at specialized disposal centers in accordance with the applicable regulations. **Subject to modifications/alterations. www.secop.com**